



MILBANK 303612-SC3R  
 CIRCLE AW 303611 RTCT  
 OR EQUIVALENT

Note: AVEC uses window style doughnut CT's

1. Cover shall be sealed.
2. Current-transformer cabinet shall not be used as a splicing chamber.
3. When exposed to weather, cabinet shall be weather tight.
4. Grounding lug for minimum No. 8 wire shall provide internally, for use of utility.
5. Consult the utility for the 800 to 1200 amp. application.
6. Customer shall install utility provided window CT's in customer supplied cabinet.

ALASKA VILLAGE ELECTRIC CO-OP  
 DISTRIBUTION ASSEMBLY GUIDE DRAWING

CURRENT-TRANSFORMER CABINET

REV. DATE
SCALE NONE
DATE 6-2-04

APPLICATION	ACCT. NO.	SPEC. NO.	DWG. RIL ENGR. M.E.T.	CAD# D2004-19	SHT 1 of 1
-------------	-----------	-----------	--------------------------	------------------	---------------