



The purpose of this, “DUAL - ACCESS CABLE LOOP” is to allow access by both the consumer and AVEC to operate the disconnect switch

WHEN THE DISCONNECT IS USED AS A LOCK - OUT POINT, THE DUAL CABLE ACCESS LOOP SHALL BE REMOVED AND THE INDIVIDUAL SHALL PLACE HIS OWN PERSONAL LOCK ON THE DISCONNECT SWITCH.

When the consumer has not provided a lock prior to the AVEC lineman energizing the service, then the lineman will install a keyless padlock. The consumer can replace the keyless padlock with a normal padlock. The keyless padlock can be readily removed with a bolt cutter, saw, or heavy pair of wire cutters.

The DUAL ACCESS CABLE LOOP ‘s purpose is to prevent nuisance disconnection of power by children, while providing access to the disconnect for both the consumer and AVEC personnel without coordinating access.

The DUAL ACCESS CABLE LOOP is manufactured with materials that will break if subjected to an aggressive operation of the disconnect switch, thus allowing opening the disconnect by a motivated individual.

ALASKA VILLAGE ELECTRIC CO-OP DISTRIBUTION ASSEMBLY GUIDE DRAWING					REV. DATE
SERVICE ENTRANCE DUAL-ACCESS CABLE LOOP					SCALE NONE
DUAL-ACCESS CABLE LOOP					DATE 11-14-06
APPLICATION	ACCT. NO.	SPEC. NO.	DWG. RIL ENGR. G.E.	CAD# D2006-24	SHT 1 of 1